## *Power evacuation capacity available in MSETCL substations as on 12.10.2026*

***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| Sr. No. | Name of Substation | Dist. | Latitude | Longitude | Cluster Capacity (MW) |
|---|---|---|---|---|---|
| 1 | 220/132/33kV Kawalewada | Gondia | 21.440995 | 79.887583 | **80** |
| 2 | 132/33/11kV Gondia | Gondia | 21.47807 | 80.13654 | |
| 3 | 132/33kV Amgaon | Gondia | 21.37273 | 80.39122 | |
| 4 | 132/33/11kV Madgi | Bhandara | 21.33576 | 79.779193 | **80** |
| 5 | 220/132/33/11kV Bhandara | Bhandara | 21.230526 | 79.6402 | **200** |
| 6 | 132/33kV Sakoli | Bhandara | 21.090255 | 80.000614 | **80** |
| 7 | 132/33kV Kardha | Bhandara | 21.1388 | 79.673 | |
| 8 | 132/33kV Gose khurd | Bhandara | 20.874845 | 79.621687 | |
| 9 | 132/33kV Asgaon | Bhandara | 20.803388 | 79.725639 | |
| 10 | 132/33kV Lakhandur | Bhandara | 20.763221 | 79.889557 | |
| 11 | 132/33kV Bramhapuri | Chandrapur | 20.62217 | 79.84809 | |
| 12 | 132/33kV Morgaon Arjuni | Gondia | | | |
| 13 | 132 kV Kolari | Nagpur | 20.703821 | 79.559204 | **80** |
| 14 | 132/33kV Ambhora | Nagpur | 21.01503 | 79.59955 | |
| 15 | 220/132/33/11kV Kanhan | Nagpur | 21.224745 | 79.246233 | **0** |
| 16 | 220/33kV Umred | Nagpur | 20.8319 | 79.3648 | **0** |
| 17 | 132/33kV Mansar | Nagpur | 21.394211 | 79.281263 | **0** |
| 18 | 132/33kV Uppalwadi | Nagpur | 21.2016 | 79.122 | **0** |
| 19 | 132/33kV Mouda | Nagpur | 21.16341 | 79.378387 | **80** |
| 20 | 220/132/11kV Ambazari | Nagpur | 21.142967 | 78.96809 | **0** |
| 21 | 220/33kV Wardha | Wardha | 20.7277 | 78.6073 | |
| 22 | 220/33kV Butibori-III | Nagpur | 20.9371 | 78.9341 | |
| 23 | 220kV Khaperkheda -I | Nagpur | 21.2822 | 79.1131 | **0** |
| 24 | 132/33/11kV Hingna 1 | Nagpur | 21.121 | 79.007 | **80** |
| 25 | 132/33/11kV Hingna 2 | Nagpur | 21.1132 | 78.9815 | |
| 26 | 132/33/11kV Mankapur | Nagpur | 21.1852 | 79.0751 | |
| 27 | 132/33/11kV Pardi | Nagpur | 21.145 | 79.169 | |
| 28 | 220/132/33kV Butibori | Nagpur | 20.9321 | 78.947612 | **80** |
| 29 | 132/33kV Khapri | Nagpur | 21.03374 | 79.070674 | **80** |
| 30 | 132/33/11kV Besa | Nagpur | 21.1087 | 79.1256 | |
| 31 | 220/132/33/11kV Kalmeshwar | Nagpur | 21.233104 | 78.895171 | **0** |
| 32 | 132/33kV Saoner | Nagpur | 21.405286 | 78.857783 | **0** |
| 33 | 132/33/11kV Katol | Nagpur | 21.288702 | 78.593285 | **0** |
| 34 | 132/33kV Bharsingi | Nagpur | 21.348951 | 78.468821 | |

## *Power evacuation capacity available in MSETCL substations as on 12.10.2026*

***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 35 | 220/66/33kV Warora | Chandrapur | 20.2337 | 79.0187 | **0** |
| 36 | 220/33kV Wani | Yavatmal | 20.0403 | 78.9774 | **0** |
| 37 | 220/33kV Sicom | Chandrapur | 19.963 | 79.3379 | **0** |
| 38 | 132/33kV Seloo | Wardha | 20.83329 | 78.69891 | **0** |
| 39 | 132/33kV Deoli | Wardha | 20.6644 | 78.4777 | **0** |
| 40 | 220/132/33kV Hinganghat | Wardha | 20.5373 | 78.79822 | **0** |
| 41 | 220/132/33kV Bhugaon | Wardha | 20.70637 | 78.62795 | |
| 42 | 132/33kV Jam | Wardha | 20.61325 | 78.92055 | **0** |
| 43 | 132/66/33kV Ashti | Gadchiroli | 19.6654 | 79.7988 | **80** |
| 44 | 132/33kV Chamorshi | Gadchiroli | 19.976 | 79.875 | |
| 45 | 132/66/33kV Allapalli | Gadchiroli | 19.43218 | 80.05416 | |
| 46 | 132/33kV Mul | Chandrapur | 20.0662 | 79.688 | |
| 47 | 132/33kV Sindewahi | Chandrapur | 20.29404 | 79.65653 | |
| 48 | 220/33kV Tadali | Chandrapur | 20.00024 | 79.1876 | **0** |
| 49 | 220/33kV MIDC Chandrapur | Chandrapur | 19.9837 | 79.2294 | **0** |
| 50 | 220/33kV Ghugus (Matradevi) | Chandrapur | 19.9626 | 79.1225 | **0** |
| 51 | 220/33kV Ballarshah | Chandrapur | 19.87560556 | 79.34166389 | **0** |
| 52 | 220/66/33kV Gadchandur | Chandrapur | 19.7375 | 79.1572 | **0** |
| 53 | 220/132/33kV Virur | Chandrapur | 19.64418 | 79.42224 | **0** |
| 54 | 220/132/33kV Gadchiroli | Gadchiroli | 20.16842 | 79.95785 | |
| 55 | 220/132/33kV Karanja | Wardha | 21.11959 | 78.50156 | **0** |
| 56 | 220/132/11kV Amravati | Amravati | 20.9534 | 77.7739 | **0** |
| 57 | 220/33kV Badnera | Amravati | 20.8602 | 77.7569 | |
| 58 | 220/33kV Dhamangaon | Amravati | 20.8081 | 78.1515 | |
| 59 | 132/33/11kV Chandur bazar | Amravati | 21.2387 | 77.7639 | **0** |
| 60 | 132/33/11kV Achalpur | Amravati | 21.2744 | 77.5166 | |
| 61 | 132/33kV Tiwsa | Amravati | 21.0879 | 78.0695 | **0** |
| 62 | 132/33kV Talegaon | Wardha | 21.0986 | 78.2003 | |
| 63 | 132/33kV Arvi | Wardha | 20.9907 | 78.2264 | **0** |
| 64 | 132/33kV Pulgaon | Wardha | 20.71832 | 78.32365 | |
| 65 | 132/33/11kV Lalkhedi | Amravati | 20.9606 | 77.7322 | **0** |
| 66 | 132/33kV Durgwada | Akola | 20.8331 | 77.388 | |
| 67 | 220/132/33kV Nandgaonpeth | Amravati | 21.0941 | 77.9031 | **0** |
| 68 | 132/33/11kV Morshi | Amravati | 21.3272 | 78.0107 | **0** |
| 69 | 132/33/11kV Warud | Amravati | 21.4784 | 78.2657 | |
| 70 | 220/132/33kV Anjangaon-II (Vihigaon) | Amravati | 21.110449 | 77.315134 | **0** |

***Power evacuation capacity available in MSETCL substations as on 12.10.2026***

***<u>Note:</u> The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:***

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 71 | 132/33kV Daryapur | Amravati | 21.1723 | 77.3212 | **0** |
| 72 | 132/33/11kV Anjangaon | Amravati | 20.9352 | 77.3099 | **0** |
| 73 | 132/33/11kV Akot | Akola | 21.0839 | 77.0576 | |
| 74 | 132/33kV Hiwarkhed | Akola | 21.1266 | 76.8534 | |
| 75 | 220/132/33kV Akola (Apatapa) | Akola | 20.7527 | 77.0248 | **0** |
| 76 | 220kV S.Y. Paras | Akola | 20.713 | 76.7962 | **0** |
| 77 | 132/33/11kV MIDC Akola | Akola | 20.687 | 77.0545 | **0** |
| 78 | 132/33kV Murtijapur | Akola | 20.673618 | 77.358175 | |
| 79 | 220kV Malkapur | Buldhana | | | **0** |
| 80 | 220/132/33kV Balapur | Akola | 20.6749 | 76.8063 | **0** |
| 81 | 132/33/11kV Gaurakshan | Akola | 20.6975 | 77.01 | **0** |
| 82 | 132/33kV Jalgaon Jamod | Buldhana | 21.07083 | 76.512125 | **0** |
| 83 | 132/33kV Warwat Bakal | Buldhana | 21.0147 | 76.715 | **0** |
| 84 | 132/33/11kV Khamgaon | Buldhana | 20.7086 | 76.5854 | |
| 85 | 220/132/33kV Chikhali | Buldhana | 20.3519 | 76.2412 | **0** |
| 86 | 132/33kV Deulgaon Mahi | Buldhana | 20.1079 | 76.1903 | **0** |
| 87 | 132/33kV Dusrabid | Buldhana | 20.0057 | 76.3014 | |
| 88 | 132/33kV Deulgaon Raja | Buldhana | 20.017196 | 76.066867 | |
| 89 | 132kV Mantha | Jalna | 19.6654 | 76.3910 | **0** |
| 90 | 132/33kV Buldhana | Buldhana | 20.5067 | 76.2012 | **0** |
| 91 | 132/33kV Motala | Buldhana | 20.4165 | 75.9736 | |
| 92 | 132/33kV Dhad | Buldhana | 20.6853 | 76.2252 | **0** |
| 93 | 220/132kV Malegaon -II (Zodga) | Washim | 20.189471 | 77.043161 | **0** |
| 94 | 132/33kV Washim | Washim | 20.1115 | 77.162 | **0** |
| 95 | 132/33kV Manglurpir | Washim | 20.295 | 77.3219 | |
| 96 | 132/33kV Karanja lad | Washim | 20.4657 | 77.5233 | |
| 97 | 132/33kV Malegaon tn. | Washim | 20.2347 | 76.9833 | **0** |
| 98 | 132/33kV Mehkar | Buldhana | 20.1539 | 76.5762 | **0** |
| 99 | 132/33kV Risod | Washim | 19.9795 | 76.7711 | **0** |
| 100 | 132kV Jintur | Parbhani | 19.6130 | 76.6800 | **0** |
| 101 | 132/33kV Patur | Akola | 20.4791 | 76.9009 | **0** |
| 102 | 220/132/33kV Yavatmal | Yavatmal | 20.3852 | 78.1535 | **0** |
| 103 | 132/33kV Pandharkawda | Yavatmal | 20.0228 | 78.5383 | **0** |
| 104 | 132/33kV Ghatanji | Yavatmal | 20.1515 | 78.3223 | |
| 105 | 132/33kV Ralegaon | Yavatmal | | | **0** |
| 106 | 132/33kV MIDC Yavatmal | Yavatmal | 20.378011 | 78.06859 | **0** |

## *Power evacuation capacity available in MSETCL substations as on 12.10.2026*

***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 107 | 220/132/33kV Ghatodi | Yavatmal | 19.9784 | 77.5912 | **0** |
| 108 | 132/33kV Darwha | Yavatmal | 20.3042 | 77.7778 | |
| 109 | 132/33kV Digras | Yavatmal | 20.1176 | 77.6821 | **0** |
| 110 | 132/33kV Arni | Yavatmal | 20.138149 | 77.95359 | |
| 111 | 132/33kV Jambazar | Yavatmal | 19.9545 | 77.5001 | **0** |
| 112 | 220/132/33kV Pusad | Yavatmal | 19.8962 | 77.5515 | **0** |
| 113 | 132/33kV Gunj | Yavatmal | 19.8544 | 77.7268 | |
| 114 | 132kV Umarkhed | Yavatmal | 19.586 | 77.687 | **0** |
| 115 | 220kV Bhokar | Nanded | 19.1994 | 77.6623 | **0** |
| 116 | 132kV Kinwat | Nanded | 19.6065 | 78.2063 | |
| 117 | 132kV Himayatnagar | Nanded | 19.4239 | 77.8894 | **0** |
| 118 | 220 kV Waghala | Nanded | 19.0969 | 77.3214 | **0** |
| 119 | 220kV Krishnoor | Nanded | 18.9272 | 77.5019 | **0** |
| 120 | 132kV Tamsa | Nanded | 19.3789 | 77.6050 | **0** |
| 121 | 132kV Umri | Nanded | 19.0479 | 77.6537 | **0** |
| 122 | 132kV Kundalwadi | Nanded | 18.8184 | 77.7769 | **0** |
| 123 | 132kV Mukhed | Nanded | 18.7215 | 77.3910 | **0** |
| 124 | 132kV Kandhar | Nanded | 18.8758 | 77.1781 | **0** |
| 125 | 132kV Degloor | Nanded | 18.6075 | 77.5702 | **0** |
| 126 | 132kV Narsi | Nanded | 18.7588 | 77.5654 | **0** |
| 127 | 132kV Jangamwadi | Nanded | 19.1810 | 77.3013 | **80** |
| 128 | 132kV Ardhapur | Nanded | 19.2775 | 77.3742 | **80** |
| 129 | 132kV Elichpur | Nanded | 19.1371 | 77.3556 | **80** |
| 130 | 220 kV Hingoli | Hingoli | 19.6924 | 77.1032 | **0** |
| 131 | 132kV Hingoli | Hingoli | 19.7334 | 77.1530 | **0** |
| 132 | 132kV Kurunda | Hingoli | 19.4080 | 77.2161 | **0** |
| 133 | 132kV Akhadabalapur | Hingoli | 19.5787 | 77.4010 | **0** |
| 134 | 132kV Basmath | Hingoli | 19.3228 | 77.1413 | **80** |
| 135 | 132kV Purna | Parbhani | 19.1754 | 77.0430 | **80** |
| 136 | 132kV Sengaon | Hingoli | 19.8350 | 76.8764 | **0** |
| 137 | 220 kV Parbhani | Parbhani | 19.2674 | 76.8069 | **0** |
| 138 | 132kV Parbhani | Parbhani | 19.2797 | 76.7605 | **0** |
| 139 | 132kV Pathri | Parbhani | 19.2784 | 76.4325 | **0** |
| 140 | 132kV Gangakhed | Parbhani | 18.9494 | 76.7362 | **0** |
| 141 | 132kV Sonpeth | Parbhani | 18.9697 | 76.4935 | **0** |
| 142 | 220 kV Harangul | Latur | 18.3875 | 76.5004 | **0** |

## *Power evacuation capacity available in MSETCL substations as on 12.10.2026*

***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 143 | 132kV Latur (Koyna) | Latur | 18.3921 | 76.5901 | **0** |
| 144 | 132kV Latur MIDC | Latur | 18.4217 | 76.5401 | **0** |
| 145 | 132kV Ahmedpur | Latur | 18.7027 | 76.9238 | **0** |
| 146 | 132kV Renapur | Latur | 18.5006 | 76.5820 | **0** |
| 147 | 132kV Chakur | Latur | 18.5233 | 76.8801 | **0** |
| 148 | 132kV Udgir | Latur | 18.3616 | 77.1311 | **0** |
| 149 | 220 kV Narangwadi | Osmanabad | 17.0863 | 76.5847 | **0** |
| 150 | 132kV Killari | Latur | 18.0570 | 76.5869 | **0** |
| 151 | 132kV Nilanga | Latur | 18.1224 | 76.7672 | **0** |
| 152 | 132kV Omerga | Osmanabad | 17.8353 | 76.6402 | **0** |
| 153 | 132kV Ausa | Latur | 18.2575 | 76.5140 | |
| 154 | 132kV Ujani | Latur | 18.1172 | 76.3090 | |
| 155 | 132kV Niwali | Latur | 18.3755 | 76.3101 | **0** |
| 156 | 220 kV Jalkot | Latur | 18.5907 | 77.2089 | **0** |
| 157 | 132kV Majalgaon | Beed | 19.1691 | 76.1961 | **0** |
| 158 | 132kV Pangari | Beed | 18.8765 | 76.4694 | **0** |
| 159 | 132kV Telgaon | Beed | 18.9887 | 76.1789 | **0** |
| 160 | 132kV Parli | Beed | 18.8713 | 76.5264 | **0** |
| 161 | 220 kV Georai | Beed | | | **0** |
| 162 | 132kV Beed | Beed | 18.9913 | 75.7742 | **0** |
| 163 | 132kV Georai | Beed | 19.2585 | 75.7577 | **0** |
| 164 | 132kV Mahakala | Jalna | 19.3986 | 75.7051 | **0** |
| 165 | 132kV Raimoha | Beed | 18.9942 | 75.5188 | **0** |
| 166 | 220kV Girwali | Beed | 18.7489 | 76.4561 | |
| 167 | 220kV OLD GCR Parli | Beed | 18.8708 | 76.5239 | |
| 168 | 220kV New GCR Parli | Beed | 18.9070 | 76.5400 | |
| 169 | 220kV Parli Unit No. 8 | Beed | 18.9132 | 76.5511 | **0** |
| 170 | 220 kV Manjarsumba | Beed | 18.8256 | 75.7473 | |
| 171 | 220 kV Patoda | Beed | 18.8070 | 75.4978 | |
| 172 | 220kV Beed | Beed | 18.9913 | 75.7742 | **0** |
| 173 | 132kV Kaij | Beed | 18.7169 | 76.0776 | |
| 174 | 132kV Kallamb | Osmanabad | 18.5681 | 76.0138 | |
| 175 | 132kV Bhoom | Osmanabad | 18.4637 | 75.6692 | **0** |
| 176 | 132/33kV Kharda | Ahmednagar | 18.64830 | 75.47270 | **0** |
| 177 | 220 kV Osmanabad | Osmanabad | 18.1870 | 76.0536 | |
| 178 | 220 kV Barshi | Solapur | 18.2502 | 75.7014 | **0** |

## *Power evacuation capacity available in MSETCL substations as on 12.10.2026*

***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 179 | 220 kV Paranda | Osmanabad | 18.2870 | 75.4549 | |
| 180 | 220 kV Tuljapur | Osmanabad | 17.9540 | 76.0270 | |
| 181 | 220 kV Murud | Latur | 18.4012 | 76.2279 | **0** |
| 182 | 132kV Naldurg | Osmanabad | 17.8189 | 76.2621 | **0** |
| 183 | 132kV Akkalkot | Solapur | 17.5282 | 76.199 | |
| 184 | 132kV Waghdari | Solapur | | | |
| 185 | 220 kV Partur | Jalna | 19.6094 | 76.2437 | **0** |
| 186 | 132kV Partur | Jalna | 19.5952 | 76.2127 | **0** |
| 187 | 220 kV Nagewadi | Jalna | 19.8792 | 75.8336 | **0** |
| 188 | 220kV Jalna | Jalna | 19.8584 | 75.8442 | **0** |
| 189 | 132kV Jalna (MIDC) | Jalna | 19.8515 | 75.8609 | |
| 190 | 132kV Jalna (Old) | Jalna | 19.8674 | 75.9046 | |
| 191 | 132kV Jafrabad | Jalna | 20.2054 | 76.0088 | **0** |
| 192 | 132kV Ambad | Jalna | 19.6164 | 75.7985 | **0** |
| 193 | 132kV Ghansawangi | Jalna | 19.5163 | 75.9895 | **0** |
| 194 | 132kV Badnapur | Jalna | 19.8653 | 75.7473 | **0** |
| 195 | 132kV Rajur | Jalna | 20.0474 | 75.8596 | **0** |
| 196 | 220 kV Phulambri | Aurangabad | 20.1181 | 75.4704 | **0** |
| 197 | 220 kV Bhokardhan | Jalna | 20.2462 | 75.7800 | **0** |
| 198 | 132kV Sillod | Aurangabad | 20.3155 | 75.6553 | **0** |
| 199 | 132kV Soygaon | Aurangabad | 20.5970 | 75.6056 | **0** |
| 200 | 220 kV Deogaon Rangari | Aurangabad | 20.0527 | 75.0801 | **0** |
| 201 | 220 kV Sawangi | Aurangabad | 19.9522 | 75.3401 | **0** |
| 202 | 132kV Pishor | Aurangabad | 20.3019 | 75.3542 | **0** |
| 203 | 132kV Kagzipura | Aurangabad | 19.9783 | 75.2143 | **0** |
| 204 | 132kV Kannad | Aurangabad | 20.2500 | 75.1303 | **0** |
| 205 | 220 kV Padegaon | Aurangabad | 19.8910 | 75.2879 | **0** |
| 206 | 132kV Harsool | Aurangabad | 19.9125 | 75.3495 | **0** |
| 207 | 132kV Chikalthana | Aurangabad | 19.8841 | 75.3719 | **0** |
| 208 | 132kV Paithan | Aurangabad | 19.5349 | 75.3807 | **0** |
| 209 | 132kV Waluj MIDC | Aurangabad | 19.8383 | 75.2421 | **0** |
| 210 | 132kV Gangapur | Aurangabad | 19.7131 | 75.0080 | **0** |
| 211 | 132kV Vaijapur | Aurangabad | 19.9223 | 74.7121 | **0** |
| 212 | 220 kV Shendra | Aurangabad | 19.8679 | 75.4766 | **0** |
| 213 | 220 kV Chitegaon | Aurangabad | 19.7258 | 75.2825 | **0** |
| 214 | 132kV Satara (Deolai) | Aurangabad | 19.8254 | 75.3294 | **100** |

***Power evacuation capacity available in MSETCL substations as on 12.10.2026***

***<u>Note:</u> The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:***

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 215 | 220kV Kekatnimbhora | Jalgaon | | | **0** |
| 216 | 132kV Deepnagar | Jalgaon | 21.04825 | 75.84450 | **0** |
| 217 | 132kV Savda | Jalgaon | 21.13803 | 75.89317 | **25** |
| 218 | 132kV Nimbhora | Jalgaon | 21.17342 | 75.96717 | **25** |
| 219 | 132kV Raver | Jalgaon | 21.24203 | 76.02081 | |
| 220 | 132kV Muktainagar | Jalgaon | 21.04561 | 76.04981 | |
| 221 | 132kV Bodwad | Jalgaon | 20.88411 | 75.98894 | **0** |
| 222 | 132kV Varangaon | Jalgaon | 21.03467 | 75.91911 | |
| 223 | 132/33/11kV Malkapur | Buldhana | 20.9135 | 76.2084 | **0** |
| 224 | 132kV Yawal | Jalgaon | 21.17739 | 75.70525 | **0** |
| 225 | 132kV Chopda | Jalgaon | 21.24556 | 75.30817 | |
| 226 | 132kV Jalgaon (O) | Jalgaon | 20.99856 | 75.58344 | **0** |
| 227 | 132kV New MIDC Jalgaon | Jalgaon | 20.99964 | 75.59531 | |
| 228 | 132kV Pachora | Jalgaon | 20.67975 | 75.34483 | |
| 229 | 132kV Pahur | Jalgaon | 20.69869 | 75.66919 | **0** |
| 230 | 132kV Khedi | Jalgaon | 21.01385 | 75.78621 | |
| 231 | 132/33 kV Kothali | Jalgaon | | | |
| 232 | 220kV Bambhori | Jalgaon | 21.02961 | 75.44189 | **0** |
| 233 | 132kV Dharangaon | Jalgaon | 21.01919 | 75.25772 | **0** |
| 234 | 132kV Amalner | Jalgaon | 21.02744 | 75.03636 | |
| 235 | 132kV Parola | Jalgaon | 20.88958 | 75.11164 | **0** |
| 236 | 132kV Erandol | Jalgaon | 20.91124 | 75.29580 | |
| 237 | 132kV Dhule | Dhule | 20.86500 | 74.77100 | **0** |
| 238 | 132kV Nardana | Dhule | 21.18030 | 74.82400 | **0** |
| 239 | 132kV Shirpur | Dhule | 21.35070 | 74.94650 | |
| 240 | 220kV Gangapur | Nandurbar | | | |
| 241 | 220kV Jamde | Dhule | 21.20680 | 74.34980 | |
| 242 | 220kV Valve | Dhule | 21.20400 | 74.23110 | **0** |
| 243 | 220kV Shivajinagar | Dhule | 21.07050 | 74.38180 | |
| 244 | 132kV Sakri | Dhule | 20.99540 | 74.32760 | |
| 245 | 220kV Dondaicha | Dhule | 21.3302 | 74.5441 | |
| 246 | 220kV Amalner | Jalgaon | 21.03758 | 75.08908 | **0** |
| 247 | 220kV Dhule | Dhule | 20.9333 | 74.8167 | |
| 248 | 220kV Viroda | Jalgaon | | | **0** |
| 249 | 220kV Bhadli | Jalgaon | | | **0** |
| 250 | 132kV Nandurbar | Nandurbar | 21.39980 | 74.26440 | **0** |

***Power evacuation capacity available in MSETCL substations as on 12.10.2026***

***<u>Note:</u> The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:***

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 251 | 132kV Visarwadi | Nandurbar | 21.18360 | 73.95010 | **0** |
| 252 | 132kV Dondaicha | Dhule | 21.33170 | 74.54840 | **0** |
| 253 | 220/132kV Shahada. | Nandurbar | 21.536 | 74.4601 | **0** |
| 254 | 132kV Taloda | Nandurbar | 21.58550 | 74.21430 | **0** |
| 255 | 132kV Samsherpur | Nandurbar | | | |
| 256 | 220kV Satana | Nashik | 20.57760 | 74.20170 | **0** |
| 257 | 132/33kV Taharabad | Nashik | 20.79640 | 74.11910 | **0** |
| 258 | 132/33kV Dindori | Nashik | 20.20780 | 73.82100 | **0** |
| 259 | 132kV Kalwan | Nashik | 20.48930 | 74.02870 | **0** |
| 260 | 132kV Lasalgaon | Nashik | 20.15257 | 74.21904 | **0** |
| 261 | 132kV Chandwad | Nashik | 20.27060 | 74.26320 | |
| 262 | 132kV Ozar | Nashik | 20.10750 | 73.94190 | **0** |
| 263 | 132kV Ranwad | Nashik | 20.15890 | 74.09720 | |
| 264 | 132kV Ramache Pimplas | Nashik | 20.08970 | 74.02410 | **0** |
| 265 | 132KV Adgaon | Nashik | 20.03200 | 73.87530 | **50** |
| 266 | 132kV Takali | Nashik | 19.99850 | 73.80560 | |
| 267 | 132KV Mhasrul tn | Nashik | 20.05330 | 73.78950 | |
| 268 | 132kV Satpur MIDC | Nashik | 20.00080 | 73.71820 | |
| 269 | 132kv Satpur | Nashik | 19.98950 | 73.74310 | |
| 270 | 132kV Ambad | Nashik | 19.95890 | 73.74080 | |
| 271 | 132KV Igatpuri | Nashik | 19.69540 | 73.60100 | **0** |
| 272 | 132kV Pachpatta | Nashik | 19.71100 | 73.80970 | |
| 273 | 132KV MIDC Sinnar | Nashik | 19.87140 | 73.97420 | **0** |
| 274 | 132KV Khaprale | Nashik | 19.82240 | 73.93320 | |
| 275 | 132KV Sinnar | Nashik | 19.84690 | 73.98720 | |
| 276 | 132/33/11kV Sangamner | Ahmednagar | 19.58840 | 74.19990 | **0** |
| 277 | 132/33kV Akole | Ahmednagar | 19.51930 | 74.00870 | |
| 278 | 132kV Rajur | Ahmednagar | 19.51205 | 73.91129 | |
| 279 | 132/33/11kV MIDC Nagar | Ahmednagar | 19.15114 | 74.69883 | **0** |
| 280 | 132/33/11kV Rahuri | Ahmednagar | 19.37510 | 74.64810 | |
| 281 | 132/33/11kV Newasa | Ahmednagar | 19.56140 | 74.92380 | **0** |
| 282 | 220/132/33kV Bhenda | Ahmednagar | 19.46990 | 75.01580 | **0** |
| 283 | 132/33/11kV Pathardi | Ahmednagar | 19.17893 | 75.17246 | **0** |
| 284 | 132/33kV Shevgaon | Ahmednagar | 19.36770 | 75.20260 | |
| 285 | 132kV Ghodegaon | Ahmednagar | 19.31710 | 74.85930 | |
| 286 | 220/132 /33kV Sonewadi | Ahmednagar | 19.04940 | 74.70120 | **0** |

## *Power evacuation capacity available in MSETCL substations as on 12.10.2026*

***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 287 | 220132kV Belwandi | Ahmednagar | 18.68460 | 74.62640 | **0** |
| 288 | 132kV Ashti | Beed | 18.8064 | 75.1653 | **0** |
| 289 | 132/33kV Khandake | Ahmednagar | 19.08910 | 74.87750 | **0** |
| 290 | 132/33/11kV Kedgaon | Ahmednagar | 19.06810 | 74.71460 | **0** |
| 291 | 132/33kV Supa | Ahmednagar | 18.95220 | 74.53870 | |
| 292 | 132kV Wadzire | Ahmednagar | | | |
| 293 | 132kV Shirur | Pune | 18.8269 | 74.3681 | |
| 294 | 132kV Kuruli | Pune | 18.6012 | 74.4292 | |
| 295 | 220/132 /33kV Kopargaon | Ahmednagar | 19.89840 | 74.48490 | **0** |
| 296 | 220/132kV Manmad | Nashik | 20.26972 | 74.45597 | **0** |
| 297 | 132KV Yeola | Nashik | 20.05230 | 74.47800 | **0** |
| 298 | 220kV Chalisgaon | Jalgaon | 20.446 | 74.9817 | **0** |
| 299 | 132kV Chalisgaon | Jalgaon | 20.45110 | 74.98510 | **0** |
| 300 | 132kV Pimperkhed | Nashik | 20.30630 | 74.75490 | **0** |
| 301 | 220kV Malegaon | Nashik | 20.5524 | 74.4849 | **0** |
| 302 | 220KV Kalwan Bhendi | Nashik | 20.50461 | 74.07676 | |
| 303 | 132kV Malegaon | Nashik | 20.56040 | 74.50210 | **0** |
| 304 | 132kV Nampur | Nashik | 20.72360 | 74.31100 | **0** |
| 305 | 220kV Sayne | Nashik | 20.56105 | 74.59520 | **0** |
| 306 | 132/33kV Karjat | Ahmednagar | 18.56720 | 74.99957 | **0** |
| 307 | 132/33kV Rashin | Ahmednagar | 18.46430 | 74.80070 | |
| 308 | 132kV Karmala | Solapur | 18.440664 | 75.189506 | |
| 309 | 132/33/11kV Shrigonda | Ahmednagar | 18.60780 | 74.69240 | **0** |
| 310 | 132kV Alegaon | Pune | 18.4248771 | 74.6342881 | |
| 311 | 132kV Daund | Pune | 18.461039 | 74.569338 | |
| 312 | 220kV Alephata | Pune | 19.1804 | 74.1104 | **0** |
| 313 | 220kV Kathapur | Pune | 18.9728 | 74.1026 | |
| 314 | 132kV Narayangaon | Pune | 19.1073 | 73.9713 | **80** |
| 315 | 132kV Chakan | Pune | 18.7719 | 73.8419 | |
| 316 | 132kV Pimpalgaon | Pune | 19.1881 | 73.7086 | **100** |
| 317 | 132kV Kavthe Yamai | Pune | | | |
| 318 | 220kV Chakan II | Pune | 18.792492 | 73.758107 | **50** |
| 319 | 220kV Bhosari I | Pune | 18.632 | 73.832 | **250** |
| 320 | 220kV Bhosari II | Pune | 18.628212 | 73.839329 | |
| 321 | 220kV Telco | Pune | 18.6568 | 73.8125 | |
| 322 | 220kV Khadki | Pune | 18.5772 | 73.854 | |

***Power evacuation capacity available in MSETCL substations as on 12.10.2026***

***<u>Note:</u> The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:***

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 323 | 220kV VSNL | Pune | 18.59855 | 73.869026 | |
| 324 | 220kV Chinchwad | Pune | 18.638 | 73.774 | |
| 325 | 220kV Chinchwad II | Pune | | | |
| 326 | 132kV Markal | Pune | 18.669 | 73.9166 | **50** |
| 327 | 132kV Rahatni | Pune | 18.5969 | 73.7813 | |
| 328 | 132kV NCL | Pune | 18.5501 | 73.8055 | |
| 329 | 132kV Kothrud | Pune | 18.4965 | 73.8175 | **100** |
| 330 | 132kV Ganeshkhind | Pune | 18.5393 | 73.8306 | |
| 331 | 132kV Varasgaon | Pune | 18.3875 | 73.6139 | |
| 332 | 100kV Talegaon | Pune | 18.7283 | 73.6716 | |
| 333 | 100kV lonawala | Pune | 18.7603 | 73.4339 | |
| 334 | 100kV Andra lake | Pune | 18.514677 | 73.342051 | **0** |
| 335 | 100kV Pawna | Pune | 18.6819 | 73.4951 | |
| 336 | 220kV Hinjewadi I | Pune | 18.5859 | 73.7371 | |
| 337 | 220kV Hinjewadi II | Pune | 18.5879 | 73.7062 | **100** |
| 338 | 220kV Pirangut | Pune | 18.523900 | 73.669100 | |
| 339 | 220kV Urse | Pune | 18.7201 | 73.6411 | |
| 340 | 220kV Talegaon Ambi | Pune | 18.7789 | 73.6877 | **100** |
| 341 | 220kV Sahara | Pune | | | |
| 342 | 220kV Nanded City | Pune | 18.464149 | 73.798878 | **150** |
| 343 | 220kV Kondhwa GIS | Pune | 18.42634 | 73.897775 | |
| 344 | 220kV Parvati | Pune | 18.4909 | 73.8357 | **100** |
| 345 | 132kV Rastapeth GIS | Pune | 18.5194 | 73.8701 | |
| 346 | 220kV Jejuri | Pune | 18.264169 | 74.172415 | **100** |
| 347 | 220kV Phursungi | Pune | 18.4754 | 73.9555 | |
| 348 | 132kV Mundhwa | Pune | 18.522 | 73.9169 | **80** |
| 349 | 132kV Phursungi | Pune | 18.4788 | 73.9568 | |
| 350 | 132kV Kamthadi | Pune | 18.2573 | 73.9022 | **25** |
| 351 | 132kV Shirwal | Satara | 18.1253 | 73.9863 | |
| 352 | 220kV Theur | Pune | 18.517 | 74.0468 | **100** |
| 353 | 220kV Magarpatta | Pune | 18.5229 | 73.9373 | |
| 354 | 132kV Kharadi | Pune | 18.5679 | 73.9336 | **80** |
| 355 | 132kV Yawat | Pune | 18.472407 | 74.283725 | **0** |
| 356 | 132kV Janai | Pune | 18.3926612 | 74.4098385 | |
| 357 | 132kV Purandar | Pune | | | **0** |
| 358 | 220kV Rajangaon | Pune | 18.7881852 | 74.2867 | **100** |

| *Power evacuation capacity available in MSETCL substations as on 12.10.2026* | | | | | |
|---|---|---|---|---|---|
| ***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*<br>***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***<br>***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***<br>***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***<br>***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***<br>***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.*** | | | | | |
| 359 | 132kV Sanaswadi | Pune | 18.643 | 74.0982 | **50** |
| 360 | 220kV Walchandnagar | Pune | 18.0341 | 74.7893 | **80** |
| 361 | 132kV Walchandnagar | Pune | 18.077388 | 74.774557 | |
| 362 | 132kV Indapur | Pune | 18.1221847 | 75.0247654 | |
| 363 | 132kV Purandwade | Solapur | 17.8684 | 74.8569 | **25** |
| 364 | 132kV Bawda | Pune | 17.9724598 | 75.0015985 | |
| 365 | 220kV Baramati | Pune | 18.180825 | 74.602486 | **200** |
| 366 | 132kV Baramati | Pune | 18.1672 | 74.5939 | |
| 367 | 220kV Kurkambh | Pune | 18.410314 | 74.501476 | **0** |
| 368 | 220kV Shirsuphal | Pune | 18.319986 | 74.568876 | |
| 369 | 220kV Bhigwan | Pune | 18.305026 | 74.758416 | **100** |
| 370 | 220kV Loni Deokar | Pune | 18.105459 | 74.544915 | |
| 371 | 220kV Jeur | Solapur | 18.263 | 75.1516 | **100** |
| 372 | 220kV Tembhurni | Solapur | 18.034492 | 75.223837 | |
| 373 | 220kV Malinagar | Solapur | 17.8987 | 75.0512 | |
| 374 | 132kV Parewadi | Solapur | 18.3024 | 74.9629 | **80** |
| 375 | 132kV Kurdwadi | Solapur | 18.0988 | 75.4321 | **50** |
| 376 | 132kV Shankarnagar | Solapur | 17.8623 | 75.0092 | **50** |
| 377 | 132kV Velapur | Solapur | 17.7971 | 75.0499 | |
| 378 | 220kV Pandharpur | Solapur | 17.654838 | 75.325034 | **0** |
| 379 | 220kV Karkambh | Solapur | 17.8616 | 75.3134 | |
| 380 | 220kV Bhalwani | Solapur | 17.708791 | 75.1241 | |
| 381 | 132kV Mangalwedha | Solapur | 17.520443 | 75.442006 | **0** |
| 382 | 132kV Nimboni | Solapur | | | **0** |
| 383 | 132kV Sangola | Solapur | 17.446432 | 75.191036 | **0** |
| 384 | 132kV Manegaon | Solapur | 17.332089 | 75.081111 | |
| 385 | 110kV Pandharpur | Solapur | 17.6568 | 75.3267 | **0** |
| 386 | 220kV Bale | Solapur | 17.7055 | 75.8796 | **25** |
| 387 | 220kV Vairag | Solapur | | | **0** |
| 388 | 132kV Mohol | Solapur | 17.7998 | 75.6384 | **25** |
| 389 | 132kV Chincholikate | Solapur | 17.741 | 75.8105 | |
| 390 | 132kV Puluj | Solapur | 17.7063 | 75.5336 | |
| 391 | 132kV Degaon | Solapur | 17.6655 | 75.871 | **25** |
| 392 | 132kV Mandrup | Solapur | 17.497935 | 75.827207 | |
| 393 | 132kV Navives | Solapur | 17.6763 | 75.8916 | |
| 394 | 132kV Soregaon | Solapur | 17.586815 | 75.883411 | |

***Power evacuation capacity available in MSETCL substations as on 12.10.2026***

***<u>Note:</u> The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:***

***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***

***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***

***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***

***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***

***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.***

| | | | | | |
|---|---|---|---|---|---|
| 395 | 132kV Karajgi | Solapur | 17.44937 | 76.048484 | |
| 396 | 132kV Solapur MIDC | Solapur | 17.6549 | 75.9361 | **50** |
| 397 | 220kV Phaltan MIDC | Satara | 18.0134 | 74.3329 | **0** |
| 398 | 220kV Lonand | Satara | 18.0450 | 74.1960 | **0** |
| 399 | 132kV Someshwar | Pune | 18.105297 | 74.2793524 | **0** |
| 400 | 132KV Phaltan | Satara | 17.9755 | 74.4544 | |
| 401 | 132kV Dahiwadi | Satara | 17.7011 | 74.5403 | **0** |
| 402 | 132kV Aundh | Satara | 17.5442 | 74.3422 | |
| 403 | 132kV Satara road | Satara | 17.7640 | 74.1030 | **20** |
| 404 | 132kV Chimangaon Gota | Satara | | | |
| 405 | 132kV Wai | Satara | 17.9425 | 73.8917 | **50** |
| 406 | 220kV Ogalewadi | Satara | 17.3170 | 74.2080 | **0** |
| 407 | 110kV Mayani | Satara | 17.4508 | 74.5443 | **0** |
| 408 | 110/33kV Dighanchi | Sangli | 17.5210 | 74.9288 | |
| 409 | 110kV Kaledhone | Sangli | | | |
| 410 | 110kV Atit | Satara | 17.5308 | 74.0667 | **30** |
| 411 | 110kV Rethare | Satara | 17.1707 | 74.2543 | **50** |
| 412 | 110kV Tembhu | Satara | 17.2794 | 74.2394 | |
| 413 | 110kV Ashta | Sangli | 16.9594 | 74.4025 | |
| 414 | 110kV Borgaon | Sangli | 17.0754 | 74.3202 | |
| 415 | 110kV Vishrambag | Sangli | 16.8431 | 74.5971 | |
| 416 | 110kV Kale (T) | Satara | 17.2078 | 74.1609 | **0** |
| 417 | 110kV Warna | Sangli | | | |
| 418 | 220kV Kadegaon | Sangli | 17.2293 | 74.3634 | **0** |
| 419 | 220kV Wathar | Kolhapur | 16.8499 | 74.2869 | **50** |
| 420 | 110kV Shiroli | Kolhapur | 16.7606 | 74.2733 | **0** |
| 421 | 110kV Chambukhadi | Kolhapur | 16.6993 | 74.1866 | |
| 422 | 220kV Mudshingi (KOP - II) | Kolhapur | 16.6785 | 74.2983 | **0** |
| 423 | 110kV Bapat Camp (Kolhapur - I) | Kolhapur | 16.7141 | 74.2705 | **0** |
| 424 | 110kV Puikhadi | Kolhapur | 16.6591 | 74.1980 | |
| 425 | 110kV Kale | Kolhapur | 16.7107 | 74.0415 | |
| 426 | 110kV Gokulshirgaon | Kolhapur | 16.6366 | 74.2757 | **0** |
| 427 | 110kV Radhanagari | Sindhudurg | 16.4046 | 73.9603 | |
| 428 | 110kV Kothali | Kolhapur | 16.5788 | 74.1332 | |
| 429 | 220kV Tilwani (Ichalkaranji II) | Kolhapur | 16.7378 | 74.4058 | **0** |
| 430 | 220/33kV Five Star MIDC Kagal | Kolhapur | 16.6105 | 74.3701 | **0** |

| *Power evacuation capacity available in MSETCL substations as on 12.10.2026* | | | | | |
|---|---|---|---|---|---|
| ***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*<br>***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***<br>***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***<br>***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***<br>***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***<br>***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.*** | | | | | |
| 431 | 110kV Ichalkaranji | Kolhapur | 16.7048 | 74.4582 | **0** |
| 432 | 110kV Jaysingpur | Kolhapur | 16.7688 | 74.5339 | **0** |
| 433 | 220kV Miraj | Sangli | 16.8165 | 74.6425 | **0** |
| 434 | 220kV Mhaishal | Sangli | 16.7322 | 74.7019 | |
| 435 | 220kV Jath | Sangli | 17.0551 | 75.1980 | |
| 436 | 110kV Savlaj | Sangli | 17.1063 | 74.7711 | **0** |
| 437 | 110kV Tasgaon | Sangli | 17.0220 | 74.6026 | |
| 438 | 110kV K'Mahankal | Sangli | 16.9972 | 74.9464 | **0** |
| 439 | 110kV Kurundwad | Kolhapur | 16.6744 | 74.5934 | **20** |
| 440 | 110kV Jath (Old) | Sangli | 17.0551 | 75.1980 | **0** |
| 441 | 110kV Sankh | Sangli | 17.0743 | 75.5001 | |
| 442 | 220kV Peth | Sangli | 17.0602 | 74.2469 | **60** |
| 443 | 132kV Bambawade | Kolhapur | 16.8856 | 74.0255 | **0** |
| 444 | 132kV Shirala | Sangli | 16.9759 | 74.0541 | |
| 445 | 220kV Kharepatan | Sindhudurg | 16.5532 | 73.6294 | **50** |
| 446 | 220kV Oni | Ratnagiri | 16.7275 | 73.5862 | |
| 447 | 132kV Kudal | Sindhudurg | 15.9970 | 73.6824 | **100** |
| 448 | 132kV Talebazar | Sindhudurg | 16.3914 | 73.4864 | |
| 449 | 132kV Kankavli | Sindhudurg | 16.2572 | 73.7152 | |
| 450 | 220kV Nivali phata | Ratnagiri | 17.0577 | 73.4041 | **50** |
| 451 | 220kV Pawas | Ratnagiri | 16.9105 | 73.2993 | |
| 452 | 110kV Aarawali | Ratnagiri | 17.3166 | 73.5182 | **0** |
| 453 | 110kV Ratnagiri | Ratnagiri | 16.9980 | 73.3482 | **0** |
| 454 | 220kV Hamidwada | Kolhapur | 16.4259 | 74.2836 | **0** |
| 455 | 220kV Mumewadi | Kolhapur | 16.2569 | 74.2833 | |
| 456 | 220kV Halkarni | Kolhapur | 15.9076 | 74.3081 | |
| 457 | 220kV Bidri (Mudaltitta) | Kolhapur | 16.4286 | 74.1341 | **50** |
| 458 | 220kV Sawantwadi (Insuli) | Sindhudurg | 15.8556 | 73.8374 | |
| 459 | 220kV Malharpeth | Satara | 17.3468 | 74.0106 | **100** |
| 460 | 220kV Satara MIDC | Satara | 17.6673 | 74.0423 | |
| 461 | 132/33kV Shaha | Ahmednagar | | | **0** |
| 462 | 132/33kV Ghargaon | Ahmednagar | | | **0** |
| 463 | 220kV Amrapur (Pathardi) | Ahmednagar | | | **0** |
| 464 | 132/33kV Dhadgaon | Nandurbar | | | **25** |
| 465 | 132/33KV kARKEE | jalgaon | | | **0** |
| 465 | 220/33KV Ner | Yavatmal | | | **0** |

| *Power evacuation capacity available in MSETCL substations as on 12.10.2026* | | | | | |
|---|---|---|---|---|---|
| ***Note:** The availability of power evacuation capacity and issuance of grid connectivity will be governed by following conditions:*<br>***a) The capacity mentioned for substations is indicative only and does not guarantee the grid connectivity feasibility at that substation.***<br>***b) Grid connectivity feasibility will be confirmed after application by developer for grid connectivity and after technical feasibility & detailed Load Flow Study.***<br>***c) The availability of required feeder bays at substation, space available inside switchyard, issues of line corridor, ROW, building control line etc. needs to to be checked separately at the time of joint survey for technical feasibility.***<br>***d) The data provided is given as on date which may change in future due to changes in grid structure and change in power flow dynamics at that time.***<br>***e) The grid connectivity applications will be processed as per prevailing GOM RE Policy & methodology formulated under policy and Grid Connectivity Procedure under MERC Open Access Regulation-2016.*** | | | | | |
| 466 | 220/33KV Raymond | Nashik | | | **0** |
| 467 | 220/33KV Bableshwar | Ahmednagar | | | **0** |
| 468 | 220/33KV Ghatnandre | Sangli | | | **0** |
| 469 | 220/33KV Bothe (Kulakjai) | Satara | | | **0** |
| 470 | 132kV Ida Jawala | Osmanabad | 18.36911389 | 75.56531667 | 0 |
| 471 | 132kV Tirthpuri | Jalna | 19.47784722 | 75.93835833 | 0 |
| 472 | 132kV Samudral | Osmanabad | 17.95172222 | 76.51390556 | 0 |
| 473 | 132kV Utwad | Jalna | 19.7569 | 76.07015278 | 0 |
| 474 | 220kV Shendra DMIC | . Sambhaji Nag | 19.87475833 | 75.52646944 | 0 |
| 475 | 220kV Kurunda GIS | Hingoli | 19.40811389 | 77.21608611 | 0 |
| 476 | 400kV Girawali | Parli | 18.74751667 | 76.45746944 | 0 |
| 477 | 400kV Waluj | . Sambhaji Nag | 19.85072778 | 75.20003611 | 0 |
| 478 | 400kV Thaptitanda | . Sambhaji Nag | 19.71278056 | 75.58851111 | 0 |
| 479 | 400kV Kumbhargaon | Nanded | 19.02088889 | 77.4083 | 0 |
| 480 | 765kV Ektuni | . Sambhaji Nag | 19.70609722 | 75.62592222 | 0 |
| 481 | 400KV Dhule | Dhule | | | 0 |
| 482 | 400kV Deepnagar (Bhusawal-II) | Jalgaon | | | 0 |
| 483 | 400kV Khadka (Bhusawal-I) | Jalgaon | | | 0 |
| 484 | 220kV Nashik (GCR) Eklahare | Nashik | | | 0 |
| 485 | 220kV Nashik (OCR) Eklahare | Nashik | | | 0 |
| 486 | 220kV Pimpalgaon (Wavi) | Nashik | | | 0 |
| 487 | 400kV Babhaleshwar | Ahmednagar | | | 0 |
| 488 | 400kV Karjat | Ahmednagar | | | 0 |